



OFFICE OF THE DISTRICT FIRE OFFICER
SARJAPUR ROAD FIRE STATION
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 16/DFO/SRFS/BNG/CC/2023.

OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Services
Sarjapur Road Fire Station
Bangalore-560 035.

Date: 06/03/2023

"Annexure-2"

To,
The Authorized Signatory
M/s. Florence Academy,
Sy No. 116/2, 60/15,
Huskur main road, Near Fruit Market,
Electronic City, Bangalore-560 100.

Sir,

Sub: Issue of "Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at "M/s. Florence Academy, Sy.No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100".

Ref: 1) This office FSR No.16/Dfo/SRFS/Bng/FSR/2023. Dt:-06-02-2023.
2) Your request letter dated: 04-03-2023.

<<<<>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. Florence Academy, Sy.No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100". with a Condition to fulfill the recommendations and compliance the same within 3 months,

With reference cited (2) above, the management of "M/s. Florence Academy" had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by FSO Sarjapur road on 04/03/2023 for issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to. "M/s Florence Academy, Sy.No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100". Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report. "This report is valid for one year from the date of issue of this report and is renewable without fail."



Mr. SANJEEV JOSEPH
PRINCIPAL
FLORENCE ACADEMY
(Aff. No. 830828 & New School Code: 400001)
Huskur Main Road, Bangalore-560 100. Karnataka
Email: theflorenceacademy@gmail.com
Phone: +91 7899892496

Yours faithfully,

06/03/23

DISTRICT FIRE OFFICER
Sarjapur Road Fire Station
Bangalore-560 035.

Copy to fire station officer, sarjapur road fire station,

	OFFICE OF THE DISTRICT FIRE OFFICER SARJAPUR ROAD FIRE STATION KAIKONDRAHALLI BANGALORE-560 035.	
Email:dfosarjapur99@gmail.com		Telephone No: 080-25746123

C.NO: 16/DFO/SRFS/FSR/BNG-2023.

OFFICE OF THE DISTRICT FIRE OFFICER
 Karnataka State Fire & Emergency Service
 Sarjapura Road Fire Station
 Bangalore-560 035.

Date: 06/3/2023

To,
 The Authorized Signatory
 M/s. Florence Academy,
 Sy No. 116/2, 60/15,
 Huskur main road, Near Fruit Market,
 Electronic City, Bangalore-560 100.

ANNEXURE-B
Group B Educational Buildings

Sub: Issue of 'Fire Safety Recommendation Certificate' with respect of fire prevention, fire fighting and evacuation measures required at "M/s. Florence Academy, Sy No. 116/2,60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100."

Ref: 1. C.NO: 09/FSO/SRFS/BNG-2023. Dated: 06/03/2023.
 2. Yours Request Letter. Dated: 04/03/2023.

><>>*@*<><<

With reference to the subject cited above, the premises "M/s. Florence Academy, Sy No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100". Was inspected by FSO Sarjapur on **04-03-2023** with respect to fire prevention, fire fighting & evacuation measures to be complied in the above Premises and has submitted The details as Under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Authorized Signatory. M/s. Florence Academy, Sy No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100.
02	Name and Address of the premises.	:	M/s. Florence Academy, Sy No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100.


Mr. SANJEEV JOSEPH
PRINCIPAL
FLORENCE ACADEMY
 (Aff. No. 830628 & New School Code: 45728)
 Huskur Main Road, Electronic City
 Ankal Taluk, Bengaluru-560 100, Karnataka
 Email: theflorenceacademy@gmail.com
 Mob: +91 7899892496



03	Name and address of the Building owner	:	M/s. Florence Academy, Sy No. 116/2,60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100.
04	Number of buildings	:	One Building
05	Number of floors	:	Ground plus 3 upper floors.
06	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	08 Class Rooms,01 Reception Room, 01 Coordinator Hall, 01 Principal Office, 01 Day Care, 01 Admission Office, 01 Sick Room, 4 Rest Rooms.
	1 st floor	:	08 Class Rooms,01 Reception Room, 01 Coordinator Hall, 01 Day Care, 01 Library room, 01 Sick Room,01 Staff Room, 4 Rest Rooms.
	2 nd floor	:	08 Class Rooms,01 Reception Room, 01 Coordinator Hall, 01 Day Care, 01 Sick Room, 01 Staff Room, 4 Rest Rooms.
	3 rd floor	:	08 Class Rooms,01 Reception Room, 01 Coordinator Hall, 01 Day Care, 01 Sick Room, 01Staff Room, 4 Rest Rooms.
07	Height of the building	:	14.60 Mtrs.
08	Site area	:	2 A care 20 Gunte.
09.	Built-up area of each floor:-		
	Ground floor	:	966.00 Sq. Mtrs.
	1 st floor	:	966.00 Sq. Mtrs.
	2 nd floor	:	966.00 Sq. Mtrs.
	3 rd floor	:	966.00 Sq. Mtrs.
10.	Total built-up area	:	3,864.00 Sq. Mtrs.
11.	Surrounding properties:-		
	West (Front)	:	12.00 mtrs wide Huskur main road
	East (Rear)	:	Vacant Land.
	North (side)	:	Flipchart office.
	South (side)	:	Residential Building.



Mr. SANDEEP JOSEPH
 PRINCIPAL
FLORENCE ACADEMY
 (Att. No. 830029 & New School Circle)
 Huskur Main Road, Electronic City
 Anekal Taluk, Bengaluru-560 100.
 Email: theflorenceacademy@gmail.com
 Mob: +91 7899892454

12.	<u>Set-back area available around the building :-</u>		
	West (Front)	:	Minimum 06.00 mtrs
	East (Rear)	:	08.00 mtrs
	North (side)	:	Minimum 30.00 mtrs
	South (side)	:	6.80 mtrs

B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)		Recommendations (04)	
01.	Accessibility to the premises	The premise is accessible from 12.00 mtrs wide Huskur main road located on Eastern side the road is hardened to carry the Weight of 45.000 Kgs.		Adequate	
02.	No. of entrances	01 entrances / exit		Complied	
03.	Width of entry / exit	Entrance / Exit 08.00 mtrs has been provided.		Adequate	
04.	Diesel generators.	01 No generator of 25 KVA capacity have been installed on the open space available on the Northern side.		Complied	
05.	No. of staircases available	Nos. of staircases	:	01	Complied
		Width of staircases	:	2.40 mtrs	
		Width of treads	:	30 cm	
		Height of risers	:	15 cm	
		Nos. of riser per flight	:	10	
		Height of handrails	:	0.90 mtrs	
06.	No. lifts and capacity.	Nos. of lifts	:	01	Complied
		Capacity of lifts	:	8 passengers	

Mr. SANJEEV JOSEPH
 PRINCIPAL
 FLORENCE ACADEMY
 (Aff. No. 830628 & New School Code: 45723)
 Huskur Main Road, Electronic City Post,
 Arekat Taluk, Bengaluru-560 100. Contact
 Email: theflorenceacademy@gmail.com
 Mob: +91 7899892496

07.	Fire extinguisher	15 Nos. of ABC fire extinguishers, each Of 5 kg capacity has been provided in The Building.	Complied
08.	First aid Hose reel hose.	One Hose Reel Hose has been provided near the entrance gate, Hose Reel Hose of 19 mm size of adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5 mm size. Have been Provided.	Complied
09.	Terrace tank over respective tower terrace.	10,000 liters capacity of terrace tank has been provided.	Complied
10.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	A booster pump has been installed at the terrace level capable of delivering 900 liters of water per minute.	Complied
11.	Escape routes	Escape routes have been Marked in Which visibly to guide the students make to safer Places.	Complied
12	No Smoking Board	No smoking board has been displayed in English and kannada at inside the entry/exit of the each floor.	Complied
13	Fire Siren	A Fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
14	Nominate one fire no Nodal Officer	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied
15.	Fire order	A notice board has been displayed the Action to be taken by the school staffs in Case of an emergency with Telephone Numbers of Sarjapur Road Fire Station i.e. 25746166 & 101 and telephone numbers of nearest Ambulance Service & Management Has been displayed.	Complied


Mr. SANJEEV JOSEPH
PRINCIPAL
FLORENCE ACADEMY
 (Aff. No. 830828 & New School Code: 4)
 Hoskur Main Road, Electronic City
 At Akal Taluk, Bengaluru-560 100, K.
 Email: theflorenceacademy@gmail.com
 Mob: +91 7899892496

16.	Fire fighting training	Not trained	The staff or employees Should be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29
17	<p>General Fire precaution measures :-</p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustible waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should be not stored in the building.</p> <p>E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.</p> <p>H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.</p>		

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" to "M/s. Florence Academy, Sy No. 116/2, 60/15, Huskur main road, Near Fruit Market, Electronic City, Bangalore-560 100". Subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.


 Mr. SANJEEV JOSEPH
 PRINCIPAL
 FLORENCE ACADEMY
 (Aff. No. 830628 & New School Code: 45728)
 Huskur Main Road, Electronic City Post,
 Hoskote Taluk, Bangalore-560 100, Karnataka
 Email: f.a.academy@gmail.com
 Mob: +91 7899892400

Copy to fire station officer sarjapur road fire station

Yours faithfully,


 DISTRICT FIRE OFFICER
 Sarjapura Road Fire Station
 Bengaluru-560 035.